

Certificate



Certificate no.

CU 72130834 03

License Holder:

AEconversion GmbH & Co. KG
Geseker Strasse 3
59494 Soest
Germany

Manufacturing Plant:

AEconversion GmbH & Co. KG
Südheide 17
D-33154 Salzkotten
Germany

Test report no.: USA-VS 31280001 007

Client Reference: Jochen Mielke

Tested to: UL 1741:2010
CSA C22.2.107.1-01 (R2006)

Certified Product: Micro Inverter

License Fee - Units

Model Designation: INV500-90US; INV500-90US PLC
INV500-90US RS485

Rated Input Voltage : DC 90V max.
(MPP Voltage Range: DC 40-80V)

Rated Input Current : DC 11 A

Rated Output Voltage: AC 208V or AC 240V, 60Hz


Rated Output Current: AC 2.3A or 2.0A

Rated Power : 480W

Protection Class : I

Appendix: 1, 1-18

Licensed Test mark:



Date of Issue

(day/mo/yr)

16/01/2014